



BRACKET AND BALLAST BOX SPECIFICATIONS:

- 1) ARM AND HOOK: CAST DUCTILE IRON ALLOY #65-45-12
- 2) BOLTS ATTACHING HOOK AND ARM TO RAILING: 1/2"-13 FULLY THREADED GRADE 5 PLATED STEEL
- 3) BALLAST BOX: 14GA. ALL STEEL CONSTRUCTION
- 4) BALLAST: 1000 WATT 277 VOLT METAL HALIDE
- 5) CORD AND PLUG: #16-3 STO-W CUT 4' LONG WITH TWIST-LOCK PLUG 277 VOLT/20 AMP (NEMA L7-20P)
- 6) FACTORY APPLIED TNEMEC GR-19 FIELD STONE PAINTED FINISH.

FIXTURE TYPE: "000"



STERNER™

JOB NAME:

JOB NO.:

REF. NO.:

DATE:
04/12/94

DR.:
BRIESEMEISTER

TITLE
BRACKET AND BALLAST DETAIL
FOR ARENA LIGHTING

RATIO
8:1

NO.:

7PD03822700D

FILMED:

DR.:

DATE:

GVB

111695

DDT

ADD FINISH, BALLAST BOX, AND MTG BKT CALL OUT 11/15/95

GVB

51094

ADD STEEL CLAMP, REMOVE CONN. STRIP

ADD CONN. STRIP, MOVE BALL. BOX

ADD STEEL CLAMP, REMOVE CONN. STRIP

PUT ON NEW FORMAT

DR.:

DATE:

GVB

111695

DDT

ADD FINISH, BALLAST BOX, AND MTG BKT CALL OUT 11/15/95

GVB

51094

ADD STEEL CLAMP, REMOVE CONN. STRIP

PUT ON NEW FORMAT

DR.:

DATE:

GVB

111695

DDT

ADD FINISH, BALLAST BOX, AND MTG BKT CALL OUT 11/15/95

GVB

51094

STERNER LIGHTING SYSTEMS, INC. 7575 CORPORATE WAY EDEN PRAIRIE, MN 55344-2022 PHONE: 612.906.7300 FAX: 612.906.7338